



Certificate of Compliance

Certificate: 2342245 (LR 57020)

Master Contract: 152235

Project: 2342245

Date Issued: October 6, 2010

Issued to: Magnetrol International Inc.

5300 Belmont Rd
Downers Grove, IL 60515
USA
Attention: Paul Snider

The products listed below are eligible to bear the CSA Mark shown



Ron Wachowicz

Issued by: Ron Wachowicz, C.E.T.

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Division 1, Groups CD; Class II, Division 1, Groups EFG:

Class I, Division 2, Groups ABCD; Class II, Division 2, Groups FG:

Ultrasonic Level Switch, Model 910-AXXX-XXX, 910-VXXX-XXX, 910-YXXX-XXX, 910-5XXX-XXX and 910-PXXX-XXX; rated 120/240 Vac, 50/60Hz, 12 Vdc, 24 Vdc, (different units), 50mA max; contact rating 10A, 28 Vdc/120 Vac, max ambient temp 71C, max working pressure 10,342 kPa: CSA Encl. 4X. Process Seal ratings: Single Seal, MWP 1500PSI (10,342kPa); Process Temperature Range is -40°C to +121°C (250°F).

Note: Model designation is followed by alpha/numeric suffixes denoting supply voltage and transducer length.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations



Certificate: 2342245 (LR 57020)

Master Contract: 152235

Project: 2342245

Date Issued: October 6, 2010

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

ANSI/ISA Std. No. 12.27.01-2003 - Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids